



**BUTLER PUBLIC SCHOOL DISTRICT  
LEAD IN DRINKING WATER  
SAMPLING REPORT**

*PERFORMED FOR:*

**BUTLER SCHOOL DISTRICT  
38 BARTHOLDI AVENUE  
BUTLER, NJ 07405**

*PERFORMED BY:*

**WESTCHESTER ENVIRONMENTAL, LLC  
1248 WRIGHTS LANE  
WEST CHESTER, PA 19380**

DECEMBER 2024



December 18, 2024

Mr. Joe Scaparro  
Butler School District  
38 Bartholdi Avenue  
Butler, NJ 07405

**Re: LEAD IN DRINKING WATER REPORT**

Dear Mr. Scaparro:

Please find enclosed the lead in drinking water initial sampling report conducted for the 2024-2025 conducted at the Butler School District.

One first draw sample analysed exceeded the action limit of 15.5 ug/L.

Thank you for giving us the opportunity to be of service. Please do not hesitate to contact us at 610-431-7545 or email [cpiccininni@westchesterenvironmental.com](mailto:cpiccininni@westchesterenvironmental.com) or [info@westchesterenvironmental.com](mailto:info@westchesterenvironmental.com).

Sincerely,

Westchester Environmental, LLC

A handwritten signature in black ink, appearing to read 'Christopher Piccininni', is written over a light blue horizontal line.

Christopher Piccininni  
Environmental Specialist



## TABLE OF CONTENTS

### BUTLER PUBLIC SCHOOL DISTRICT

1.0	EXECUTIVE SUMMARY.....	2
2.0	INTRODUCTION .....	3
3.0	SAMPLING AND ANALYSES .....	4
4.0	SAMPLE RESULTS.....	5
5.0	DISCUSSION & RECOMMENDATIONS.....	8
6.0	DISCLAIMER .....	9



## 1.0 EXECUTIVE SUMMARY

Westchester Environmental, LLC (WCE) was contracted by Mr. Joe Scaparro of the Butler Public School District to conduct lead in water testing for the school district for the 2024-2025 school year.

The water sampling was performed by Christopher Piccininni of Westchester Environmental, LLC. on November 16, 2024.

The objective of the sampling was to determine the lead in water levels associated with the various buildings across the district. During this visit, first draw and flush water samples were collected at predetermined locations from the following buildings:

1. Butler High School - 38 Bartholdi Ave., Butler NJ, 07405
2. Butler High School Art Building - 38 Bartholdi Ave., Butler NJ, 07405
3. Aaron Decker School - 98 Decker Road, Butler, NJ 07405
4. Richard Butler Middle School - 3 Pearl Place, Butler, NJ 07405

**The first draw sample collected on the 2nd floor in S-Room 55 at the Aaron Decker School exceeded** the lead action level of 15.5 microgram/liter (ug/L) or 15.5 parts per billion (ppb), based on the analysis of lead content using U.S. Environmental Protection Agency (EPA) Method 200.8 for lead in drinking water.

### **Immediate / Short Term Action Required:**

Immediately discontinue using water at the above location. If this location is going to be remediated for future use, it will need to be re-tested prior to being put in service to make sure the remedial work was successful.

*-END OF SECTION-*

## 2.0 INTRODUCTION

The objective of the sampling was to determine the lead in water levels from drinking water outlets located within the school district. The sampling was conducted at four different buildings within the district. During this visit, first draw and flush drinking water samples were collected.

Lead in school drinking water continues to be a serious concern, with children in many schools potentially drinking water with dangerous levels of lead. Even when water entering a facility meets all federal and state public health standards for lead concentrations, older plumbing materials found in schools can contribute to elevated lead levels in the drinking water.

The New Jersey Department of Environmental Protection's (NJDEP) action level for lead in drinking water is set at 15. However, for the purposes of compliance, any concentration greater than 15 µg/L (as defined as greater than or equal to 15.5 µg/L) is considered to exceed the lead action level. If sampling exceeds the level, then the action will need to be taken.

The Environmental Protection Agency (EPA) itself states that 15 ug/L is not a health-based standard, but rather based on what is feasible for water systems to achieve. According to the EPA, given present technology and resources, this level is the lowest level to which water systems can reasonably be required to control this contaminant should it be present in drinking water.

On October 8, 2024, the EPA announced the finalization of key improvements to the Lead and Copper Rule (LCR), which introduces new regulations that will reshape how public water suppliers manage lead service lines. These changes are critical to protecting public health and will become effective in late 2027, three years after their publication.

One of the most significant changes is the reduction of the lead action level to 10 ug/L. Water systems that exceed this threshold must take immediate corrective actions, including notifying the public, implementing corrosion control treatments, and expediting lead service line replacement.

*-END OF SECTION-*

### **3.0 SAMPLING AND ANALYSES**

During this sampling event four point of entry samples, sixty-three first draw samples, sixty-two flush samples and one field blank were collected.

All the collected samples were labeled with a unique identification number and transported to Suburban Laboratory for analysis of lead in drinking water using EPA Method 200.8. Suburban Testing Labs located at 1037F MacArthur Rd, Reading, PA 19605, is a NJ certified Lead in Drinking Water testing facility.

The following guidance documents were followed for sampling:

1. New Jersey Department of Education N.J.A.C. 6A:26
2. The USEPA's Revised Technical Guidance - "3Ts for Reduced Lead in Drinking Water in Schools"
3. Guidance Document from NJDEP Division of Water Supply and Geoscience – "Lead in Drinking Water: Guidance for Schools and Child Care Facilities Served by Public Water as well as the Safe Drinking Water Act of 1974".

*-END OF SECTION-*

## 4.0 SAMPLE RESULTS

The tables below show the first draw concentrations of lead (microgram per liter) at sampled locations. The NJDEP establishes 15.5 ug/L as the lead action limit.

**Table 1: Butler High School**

	Location Code	Results (ug/L)	Action Level (ug/L)	Lead Hazard (Yes/No)
1	BHS-LL-SPOE-Boys Rm Near 118-F	<1.00	15.5	No
2	BHS-ML-WC-Hall O/S Attendance	<1.00	15.5	No
3	BHS-ML-BF-Hall O/S Attendance	<1.00	15.5	No
4	BHS-ML-WC-Hall O/S 210	3.14	15.5	No
5	BHS-TL-FS-Faculty Room	<1.00	15.5	No
6	BHS-TL-BF-O/S Faculty Room	<1.00	15.5	No
7	BHS-TL-WC-O/S Faculty Room	<1.00	15.5	No

**Table 2: High School Art Building**

	Location Code	Results (ug/L)	Action Level (ug/L)	Lead Hazard (Yes/No)
8	Art Bldg-LL-SPOE-Boiler Room-F	<1.00	15.5	No
9	Art Bldg-ML-NS-Nurse	<1.00	15.5	No
10	Art Bldg-ML-NS-Nurse Patient Rm	1.31	15.5	No
11	Art Bldg-ML-S-Sky lands Rm	<1.00	15.5	No
12	Art Bldg-ML-IM-Trainers Rm	<1.00	15.5	No
13	Art Bldg-ML-S-Trainers Rm	<1.00	15.5	No
14	Art Bldg-ML-BF-Hall O/S Weight Rm	<1.00	15.5	No
15	Art Bldg-ML-WC-Cafeteria Left	<1.00	15.5	No
16	Art Bldg-ML-BF-Cafeteria Left	<1.00	15.5	No
17	Art Bldg-ML-WC-Cafeteria Right	5.84	15.5	No
18	Art Bldg-ML-WC-Boys Locker Rm	<1.00	15.5	No
19	Art Bldg-ML-BF-Boys Locker Rm	<1.00	15.5	No
20	Art Bldg-ML-WC-Girls Locker Rm	<1.00	15.5	No
21	Art Bldg-ML-BF-Girls Locker Rm	<1.00	15.5	No
22	Art Bldg-ML-WC-O/S Girls Locker Rm	2.92	15.5	No
23	Art Bldg-ML-FP-Kitchen 2	1.31	15.5	No
24	Art Bldg-ML-FP-Kitchen 3	1.05	15.5	No
25	Art Bldg-ML-FP-Kitchen 5	3.96	15.5	No
26	Art Bldg-LL-WC-Bsmt Locker RM	<1.00	15.5	No
27	Art Bldg-TL-WC-Hall O/S Rm 335 Left	5.81	15.5	No
28	Art Bldg-TL-WC-Hall O/S Rm 335 Right	2.42	15.5	No

Location Code	Results (ug/L)	Action Level (ug/L)	Lead Hazard (Yes/No)	
29	Art Bldg-TL-WC-Hall O/S Rm 336	<1.00	15.5	No
30	Art Bldg-TL-BF-Hall O/S Rm 336	<1.00	15.5	No
31	Art Bldg-TL-FP-Foods Lab 1	3.89	15.5	No
32	Art Bldg-TL-FP-Foods Lab 2	<1.00	15.5	No
33	Art Bldg-TL-FP-Foods Lab 3	<1.00	15.5	No
34	Art Bldg-TL-FP-Foods Lab 4	<1.00	15.5	No
35	Art Bldg-TL-FP-Foods Lab 5	3.53	15.5	No
36	Art Bldg-TL-FP-Foods Lab 6	1.06	15.5	No
37	Art Bldg-TL-WC-Hall O/S BOE Offices	<1.00	15.5	No
38	Art Bldg-TL-BF-Hall O/S BOE Office	<1.00	15.5	No
39	Art Bldg-TL-S-BOE Office Rm 13	<1.00	15.5	No

**Table 3: Aaron Decker School**

Location Code	Results (ug/L)	Action Level (ug/L)	Lead Hazard (Yes/No)	
40	BAD-1FL-SPOE-Kitchen-F	<1.00	15.5	No
41	BAD-1FL-FP1-Kitchen	3.43	15.5	No
42	BAD-1FL-KO-Kitchen	<1.00	15.5	No
43	BAD-1FL-WC-Hall O/S Kitchen	<1.00	15.5	No
44	BAD-1FL-BF-Hall O/S Kitchen	<1.00	15.5	No
45	BAD-1FL-NS-Nurse	<1.00	15.5	No
46	BAD-1FL-FS-Faculty Rm	<1.00	15.5	No
47	BAD-1FL-WC-Hall O/S Rm 28	<1.00	15.5	No
48	BAD-2FL-BF-Hall O/S Rm 28	<1.00	15.5	No
49	BAD-2FL-WC-Hall O/S Rm 35	<1.00	15.5	No
50	BAD--BF-Hall O/S Rm 35	<1.00	15.5	No
51	BAD--FS-Faculty Rm 36	1.03	15.5	No
52	BAD-2FL-S-Rm 35	18.0	15.5	Yes
53	BAD-2FL-S-Rm 36	6.52	15.5	No



**Table 4: Richard Butler Middle School**

	Location Code	Results (ug/L)	Action Level (ug/L)	Lead Hazard (Yes/No)
54	BRB-1FL-POE-Boiler Room-F	<1.00	15.5	No
55	BRB-1FL-FP-Special Services	2.56	15.5	No
56	BRB-1FL-FP-Kitchen	1.32	15.5	No
57	BRB-1FL-FS-Faculty 156	1.02	15.5	No
58	BRB-1FL-DW-O/S Rm 153	1.74	15.5	No
59	BRB-1FL-WC-Hall O/S Special Services-L	<1.00	15.5	No
60	BRB-1FL-BF-Hall O/S Special Services-R	<1.00	15.5	No
61	BRB-1FL-WC-Hall O/S 119 Left	<1.00	15.5	No
62	BRB-1FL-DW-Hall O/S Nurse-L	2.33	15.5	No
63	BRB-1FL-BF-Hall O/S Nurse-R	<1.00	15.5	No
64	BRB-1FL-WC-Hall O/S Nurse-R	<1.00	15.5	No
65	BRB-1FL-NS-Nurse	1.45	15.5	No
66	BRB-1FL-WC-Hall O/S Gym-L	<1.00	15.5	No
67	BRB-1FL-BF-Hall O/S Gym-L	<1.00	15.5	No
68	Field Blank	<1.00	15.5	No

*-END OF SECTION*

## 5.0 DISCUSSION & RECOMMENDATIONS

The tables below shows the first draw sample and the corresponding flush sample that exceeded the action limit of 15.5 ug/L, based on laboratory analysis of lead content using U.S. Environmental Protection Agency (EPA) Method 200.8 for lead in drinking water

### Lead Water Exceedances

#### First Draw

Building	Location Code	Results (ug/L)	Action Level (ug/L)	Lead Hazard (Yes/No)	
1	Aaron Decker School	BAD-2FL-S-RM 35	18.8	15.5	Yes

#### Flush Draw

Building	Location Code	Results (ug/L)	Action Level (ug/L)	Lead Hazard (Yes/No)	
1	Aaron Decker School	BAD-2FL-S-RM 35	5.71	15.5	No

### Action Required:

1. Immediately discontinue using water at the location that exceeded the NJDEP 15.5 ug/L Action Level. If this location is going to be remediated for future use, it will need to be re-tested prior to being put in service to make sure the remedial work was successful
2. Refer to EPA's "**3Ts for Reducing Lead in Drinking Water in Schools and Child Care Facilities**" for other short term and long term suggested remediation measures and notification procedures.
3. Schedule a sampling for remediated points. A new first and flush sample will be collected to determine the success or failure of the chosen remediation. If the location is decommissioned permanently, no further sampling will be needed.

*-END OF SECTION-*

## 6.0 DISCLAIMER

The type of samples collected for this assessment are referred to as grab samples. Grab samples are individual discrete samples collected at a specific time and location.

No guarantee or warranty of the findings and conclusions is implied within the intent of this report. It is limited to only those items listed in the report and is a snapshot of the conditions existing at the time of the assessment as conditions may vary with time.

WCE assumes no liability with regards to decisions made or the use of any information contained in this report, which is prepared exclusively for and is confidential to the above noted client. These services are designed to provide an analytical tool to assist the client, and the user(s) of this information must use their own best judgment to determine the appropriate course of action.

Westchester Environmental LLC



Christopher Piccininni  
Environmental Specialist

*-END OF REPORT-*

## **APPENDIX I**

**LEAD IN DRINKING WATER SAMPLING  
CHAINS-OF-CUSTODY & LAB REPORTS**



### Results Report

Order ID: 4K04433

Westchester Environmental  
1248 Wrights Lane  
West Chester, PA 19380

Project: Butler SD High School, Decker, & Butler  
38 Bartholdi Ave  
Butler, NJ 07405

Attn: Christopher Piccininni

Regulatory ID:

Sample Number: 4K04433-01	Site: BHS-LL-SPOE-Boys Rm Near 118-F	Sample ID: Flush 001								
Collector: CMP	Collect Date: 11/16/2024 7:00 am	Sample Type: Grab								
Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 11/25/24 RPV 11/26/24 18:50 RBP

Sample Number: 4K04433-02	Site: BHS-ML-WC-Hall O/S Attendance	Sample ID: First 002								
Collector: CMP	Collect Date: 11/16/2024 7:04 am	Sample Type: Grab								
Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 11/25/24 RPV 11/26/24 18:52 RBP

Sample Number: 4K04433-03	Site: BHS-ML-BF-Hall O/S Attendance	Sample ID: First 003								
Collector: CMP	Collect Date: 11/16/2024 7:06 am	Sample Type: Grab								
Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 11/25/24 RPV 11/26/24 18:54 RBP

Sample Number: 4K04433-04	Site: BHS-ML-WC-Hall O/S 210	Sample ID: First 004								
Collector: CMP	Collect Date: 11/16/2024 7:08 am	Sample Type: Grab								
Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By

Metals

Lead 3.14 µg/L EPA 200.8 1.00 1 11/25/24 RPV 11/26/24 18:56 RBP

Sample Number: 4K04433-05	Site: BHS-TL-FS-Faculty Room	Sample ID: First 005								
Collector: CMP	Collect Date: 11/16/2024 7:10 am	Sample Type: Grab								
Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 11/25/24 RPV 11/26/24 18:58 RBP

Report Generated On: 12/06/2024 3:53 pm 4K04433  
STL\_Results Revision #3.0 Effective: 05/29/2024





# SUBURBAN TESTING LABS

Sample Number: 4K04433-06      Site: BHS-TL-BF-O/S Faculty Room      Sample ID: First 006  
 Collector: CMP      Collect Date: 11/16/2024 7:12 am      Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

### Metals

Lead < 1.00      µg/L      EPA 200.8      1.00      1      11/25/24      RPV      11/26/24 19:00      RBP

Sample Number: 4K04433-07      Site: BHS-TL-WC-O/S Faculty Room      Sample ID: First 007  
 Collector: CMP      Collect Date: 11/16/2024 7:14 am      Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

### Metals

Lead < 1.00      µg/L      EPA 200.8      1.00      1      11/25/24      RPV      11/26/24 19:02      RBP

Sample Number: 4K04433-08      Site: Art Bldg-LL-SPOE-Boiler Room-F      Sample ID: Flush 008  
 Collector: CMP      Collect Date: 11/16/2024 7:16 am      Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

### Metals

Lead < 1.00      µg/L      EPA 200.8      1.00      1      11/25/24      RPV      11/26/24 19:04      RBP

Sample Number: 4K04433-09      Site: Art Bldg-ML-NS-Nurse      Sample ID: First 009  
 Collector: CMP      Collect Date: 11/16/2024 7:20 am      Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

### Metals

Lead < 1.00      µg/L      EPA 200.8      1.00      1      11/25/24      RPV      11/26/24 18:39      RBP

Sample Number: 4K04433-10      Site: Art Bldg-ML-NS-Nurse Patient Rm      Sample ID: First 010  
 Collector: CMP      Collect Date: 11/16/2024 7:22 am      Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

### Metals

Lead 1.31      µg/L      EPA 200.8      1.00      1      11/25/24      RPV      11/26/24 19:06      RBP

Sample Number: 4K04433-11      Site: Art Bldg-ML-S-Sky lands Rm      Sample ID: First 011  
 Collector: CMP      Collect Date: 11/16/2024 7:24 am      Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

### Metals

Lead < 1.00      µg/L      EPA 200.8      1.00      1      11/25/24      RPV      11/26/24 19:12      RBP

Sample Number: 4K04433-12      Site: Art Bldg-ML-IM-Trainers Rm      Sample ID: First 012  
 Collector: CMP      Collect Date: 11/16/2024 7:26 am      Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

### Metals

Lead < 1.00      µg/L      EPA 200.8      1.00      1      11/25/24      RPV      11/26/24 19:14      RBP

Report Generated On: 12/06/2024 3:53 pm      4K04433  
 STL\_Results      Revision #3.0      Effective: 05/29/2024





# SUBURBAN TESTING LABS

Sample Number: 4K04433-13      Site: Art Bldg-ML-S-Trainers Rm      Sample ID: First 013  
 Collector: CMP      Collect Date: 11/16/2024 7:28 am      Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
Metals										
Lead	< 1.00	µg/L	EPA 200.8	1.00		1	11/25/24	RPV	11/26/24 19:16	RBP

Sample Number: 4K04433-14      Site: Art Bldg-ML-BF-Hall O/S Weigth Rm      Sample ID: First 014  
 Collector: CMP      Collect Date: 11/16/2024 7:30 am      Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
Metals										
Lead	< 1.00	µg/L	EPA 200.8	1.00		1	11/25/24	RPV	11/26/24 19:18	RBP

Sample Number: 4K04433-15      Site: Art Bldg-ML-WC-Cafeteria Left      Sample ID: First 015  
 Collector: CMP      Collect Date: 11/16/2024 7:32 am      Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
Metals										
Lead	< 1.00	µg/L	EPA 200.8	1.00		1	11/25/24	RPV	11/26/24 19:20	RBP

Sample Number: 4K04433-16      Site: Art Bldg-ML-BF-Cafeteria Left      Sample ID: First 016  
 Collector: CMP      Collect Date: 11/16/2024 7:34 am      Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
Metals										
Lead	< 1.00	µg/L	EPA 200.8	1.00		1	11/25/24	RPV	11/26/24 19:22	RBP

Sample Number: 4K04433-17      Site: Art Bldg-ML-WC-Cafeteria Right      Sample ID: First 017  
 Collector: CMP      Collect Date: 11/16/2024 7:36 am      Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
Metals										
Lead	5.84	µg/L	EPA 200.8	1.00		1	11/25/24	RPV	11/26/24 19:25	RBP

Sample Number: 4K04433-18      Site: Art Bldg-ML-WC-Boys Locker Rm      Sample ID: First 018  
 Collector: CMP      Collect Date: 11/16/2024 7:38 am      Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
Metals										
Lead	< 1.00	µg/L	EPA 200.8	1.00		1	11/25/24	RPV	11/26/24 19:27	RBP

Sample Number: 4K04433-19      Site: Art Bldg-ML-BF-Boys Locker Rm      Sample ID: First 019  
 Collector: CMP      Collect Date: 11/16/2024 7:40 am      Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
Metals										
Lead	< 1.00	µg/L	EPA 200.8	1.00		1	11/25/24	RPV	11/26/24 19:29	RBP

Report Generated On: 12/06/2024 3:53 pm      4K04433  
 STL\_Results      Revision #3.0      Effective: 05/29/2024





# SUBURBAN TESTING LABS

Sample Number: 4K04433-20	Site: Art Bldg-ML-WC-Girls Locker Rm	Sample ID: First 020
Collector: CMP	Collect Date: 11/16/2024 7:42 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

### Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00		1	11/25/24	RPV	11/26/24 19:43	RBP
------	--------	------	-----------	------	--	---	----------	-----	----------------	-----

Sample Number: 4K04433-21	Site: Art Bldg-ML-BF-Girls Locker Rm	Sample ID: First 021
Collector: CMP	Collect Date: 11/16/2024 7:44 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

### Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00		1	11/25/24	RPV	11/26/24 19:45	RBP
------	--------	------	-----------	------	--	---	----------	-----	----------------	-----

Sample Number: 4K04433-22	Site: Art Bldg-ML-WC-O/S Girls Locker Rm	Sample ID: First 022
Collector: CMP	Collect Date: 11/16/2024 7:46 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

### Metals

Lead	2.92	µg/L	EPA 200.8	1.00		1	11/25/24	RPV	11/26/24 19:47	RBP
------	------	------	-----------	------	--	---	----------	-----	----------------	-----

Sample Number: 4K04433-23	Site: Art Bldg-ML-FP-Kitchen 2	Sample ID: First 023
Collector: CMP	Collect Date: 11/16/2024 7:48 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

### Metals

Lead	1.31	µg/L	EPA 200.8	1.00		1	11/25/24	RPV	11/26/24 19:50	RBP
------	------	------	-----------	------	--	---	----------	-----	----------------	-----

Sample Number: 4K04433-24	Site: Art Bldg-ML-FP-Kitchen 3	Sample ID: First 024
Collector: CMP	Collect Date: 11/16/2024 7:50 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

### Metals

Lead	1.05	µg/L	EPA 200.8	1.00		1	11/25/24	RPV	11/26/24 19:52	RBP
------	------	------	-----------	------	--	---	----------	-----	----------------	-----

Sample Number: 4K04433-25	Site: Art Bldg-ML-FP-Kitchen 5	Sample ID: First 025
Collector: CMP	Collect Date: 11/16/2024 7:52 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

### Metals

Lead	3.96	µg/L	EPA 200.8	1.00		1	11/25/24	RPV	11/26/24 19:54	RBP
------	------	------	-----------	------	--	---	----------	-----	----------------	-----

Sample Number: 4K04433-26	Site: Art Bldg-LL-WC-Bsmt Locker RM	Sample ID: First 026
Collector: CMP	Collect Date: 11/16/2024 7:54 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

### Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00		1	11/25/24	RPV	11/26/24 19:56	RBP
------	--------	------	-----------	------	--	---	----------	-----	----------------	-----

Report Generated On: 12/06/2024 3:53 pm 4K04433  
 STL\_Results Revision #3.0 Effective: 05/29/2024







# SUBURBAN TESTING LABS

Sample Number: 4K04433-27      Site: Art Bldg-TL-WC-Hall O/S Rm 335 Left      Sample ID: First 027  
 Collector: CMP      Collect Date: 11/16/2024 7:56 am      Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

### Metals

Lead      5.81      µg/L      EPA 200.8      1.00      1      11/25/24      RPV      11/26/24 20:02      RBP

Sample Number: 4K04433-28      Site: Art Bldg-TL-WC-Hall O/S Rm 335 Right      Sample ID: First 028  
 Collector: CMP      Collect Date: 11/16/2024 7:58 am      Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

### Metals

Lead      2.42      µg/L      EPA 200.8      1.00      1      11/25/24      RPV      11/26/24 20:04      RBP

Sample Number: 4K04433-29      Site: Art Bldg-TL-WC-Hall O/S Rm 336      Sample ID: First 029  
 Collector: CMP      Collect Date: 11/16/2024 8:00 am      Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

### Metals

Lead      < 1.00      µg/L      EPA 200.8      1.00      1      11/25/24      RPV      11/26/24 19:39      RBP

Sample Number: 4K04433-30      Site: Art Bldg-TL-BF-Hall O/S Rm 336      Sample ID: First 030  
 Collector: CMP      Collect Date: 11/16/2024 8:02 am      Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

### Metals

Lead      < 1.00      µg/L      EPA 200.8      1.00      1      11/25/24      RPV      11/26/24 20:06      RBP

Sample Number: 4K04433-31      Site: Art Bldg-TL-FP-Foods Lab 1      Sample ID: First 031  
 Collector: CMP      Collect Date: 11/16/2024 8:04 am      Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

### Metals

Lead      3.89      µg/L      EPA 200.8      1.00      1      11/25/24      RPV      11/26/24 20:08      RBP

Sample Number: 4K04433-32      Site: Art Bldg-TL-FP-Foods Lab 2      Sample ID: First 032  
 Collector: CMP      Collect Date: 11/16/2024 8:06 am      Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

### Metals

Lead      < 1.00      µg/L      EPA 200.8      1.00      1      11/25/24      RPV      11/26/24 20:10      RBP

Sample Number: 4K04433-33      Site: Art Bldg-TL-FP-Foods Lab 3      Sample ID: First 033  
 Collector: CMP      Collect Date: 11/16/2024 8:08 am      Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

### Metals

Lead      < 1.00      µg/L      EPA 200.8      1.00      1      11/25/24      RPV      11/26/24 20:12      RBP

Report Generated On: 12/06/2024 3:53 pm      4K04433  
 STL\_Results      Revision #3.0      Effective: 05/29/2024





# SUBURBAN TESTING LABS

Sample Number: 4K04433-34	Site: Art Bldg-TL-FP-Foods Lab 4	Sample ID: First 034
Collector: CMP	Collect Date: 11/16/2024 8:10 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

### Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00		1	11/25/24	RPV	11/26/24 20:14	RBP
------	--------	------	-----------	------	--	---	----------	-----	----------------	-----

Sample Number: 4K04433-35	Site: Art Bldg-TL-FP-Foods Lab 5	Sample ID: First 035
Collector: CMP	Collect Date: 11/16/2024 8:12 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

### Metals

Lead	3.53	µg/L	EPA 200.8	1.00		1	11/25/24	RPV	11/26/24 20:16	RBP
------	------	------	-----------	------	--	---	----------	-----	----------------	-----

Sample Number: 4K04433-36	Site: Art Bldg-TL-FP-Foods Lab 6	Sample ID: First 036
Collector: CMP	Collect Date: 11/16/2024 8:14 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

### Metals

Lead	1.06	µg/L	EPA 200.8	1.00		1	11/25/24	RPV	11/26/24 20:19	RBP
------	------	------	-----------	------	--	---	----------	-----	----------------	-----

Sample Number: 4K04433-37	Site: Art Bldg-TL-WC-Hall O/S BOE Offices	Sample ID: First 037
Collector: CMP	Collect Date: 11/16/2024 8:16 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

### Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00		1	11/25/24	RPV	11/26/24 20:21	RBP
------	--------	------	-----------	------	--	---	----------	-----	----------------	-----

Sample Number: 4K04433-38	Site: Art Bldg-TL-BF-Hall O/S BOE Office	Sample ID: First 038
Collector: CMP	Collect Date: 11/16/2024 8:18 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

### Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00		1	11/25/24	RPV	11/26/24 20:27	RBP
------	--------	------	-----------	------	--	---	----------	-----	----------------	-----

Sample Number: 4K04433-39	Site: Art Bldg-TL-S-BOE Office Rm 13	Sample ID: First 039
Collector: CMP	Collect Date: 11/16/2024 8:20 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

### Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00		1	11/25/24	RBP	11/26/24 20:29	RBP
------	--------	------	-----------	------	--	---	----------	-----	----------------	-----

Sample Number: 4K04433-40	Site: BAD-1FL-SPOE-Kitchen-F	Sample ID: Flush 040
Collector: CMP	Collect Date: 11/16/2024 8:30 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

### Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00		1	11/25/24	RBP	11/26/24 20:39	RBP
------	--------	------	-----------	------	--	---	----------	-----	----------------	-----

Report Generated On: 12/06/2024 3:53 pm 4K04433  
 STL\_Results Revision #3.0 Effective: 05/29/2024





Sample Number: 4K04433-41	Site: BAD-1FL-FP1-Kitchen	Sample ID: First 041
Collector: CMP	Collect Date: 11/16/2024 8:34 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

Metals

Lead	3.43	µg/L	EPA 200.8	1.00		1	11/25/24	RBP	11/26/24 20:41	RBP
------	------	------	-----------	------	--	---	----------	-----	----------------	-----

Sample Number: 4K04433-42	Site: BAD-1FL-KO-Kitchen	Sample ID: First 042
Collector: CMP	Collect Date: 11/16/2024 8:36 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00		1	11/25/24	RBP	11/26/24 20:43	RBP
------	--------	------	-----------	------	--	---	----------	-----	----------------	-----

Sample Number: 4K04433-43	Site: BAD-1FL-WC-Hall O/S Kitchen	Sample ID: First 043
Collector: CMP	Collect Date: 11/16/2024 8:38 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00		1	11/25/24	RBP	11/26/24 20:46	RBP
------	--------	------	-----------	------	--	---	----------	-----	----------------	-----

Sample Number: 4K04433-44	Site: BAD-1FL-BF-Hall O/S Kitchen	Sample ID: First 044
Collector: CMP	Collect Date: 11/16/2024 8:40 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00		1	11/25/24	RBP	11/26/24 20:52	RBP
------	--------	------	-----------	------	--	---	----------	-----	----------------	-----

Sample Number: 4K04433-45	Site: BAD-1FL-NS-Nurse	Sample ID: First 045
Collector: CMP	Collect Date: 11/16/2024 8:42 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00		1	11/25/24	RBP	11/26/24 20:54	RBP
------	--------	------	-----------	------	--	---	----------	-----	----------------	-----

Sample Number: 4K04433-46	Site: BAD-1FL-FS-Faculty Rm	Sample ID: First 046
Collector: CMP	Collect Date: 11/16/2024 8:44 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00		1	11/25/24	RBP	11/26/24 20:56	RBP
------	--------	------	-----------	------	--	---	----------	-----	----------------	-----

Sample Number: 4K04433-47	Site: BAD-1FL-WC-Hall O/S Rm 28	Sample ID: First 047
Collector: CMP	Collect Date: 11/16/2024 8:46 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00		1	11/25/24	RBP	11/26/24 20:58	RBP
------	--------	------	-----------	------	--	---	----------	-----	----------------	-----

Report Generated On: 12/06/2024 3:53 pm 4K04433  
STL\_Results Revision #3.0 Effective: 05/29/2024





# SUBURBAN TESTING LABS

Sample Number: 4K04433-48	Site: BAD-2FL-BF-Hall O/S Rm 28	Sample ID: First 048
Collector: CMP	Collect Date: 11/16/2024 8:48 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

### Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00		1	11/25/24	RBP	11/26/24 21:00	RBP
------	--------	------	-----------	------	--	---	----------	-----	----------------	-----

Sample Number: 4K04433-49	Site: BAD-2FL-WC-Hall O/S Rm 35	Sample ID: First 049
Collector: CMP	Collect Date: 11/16/2024 8:50 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

### Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00		1	11/25/24	RBP	11/26/24 20:35	RBP
------	--------	------	-----------	------	--	---	----------	-----	----------------	-----

Sample Number: 4K04433-50	Site: BAD--BF-Hall O/S Rm 35	Sample ID: First 050
Collector: CMP	Collect Date: 11/16/2024 8:52 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

### Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00		1	11/25/24	RBP	11/26/24 21:02	RBP
------	--------	------	-----------	------	--	---	----------	-----	----------------	-----

Sample Number: 4K04433-51	Site: BAD--FS-Faculty Rm 36	Sample ID: First 051
Collector: CMP	Collect Date: 11/16/2024 8:54 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

### Metals

Lead	1.03	µg/L	EPA 200.8	1.00		1	11/25/24	RBP	11/26/24 21:04	RBP
------	------	------	-----------	------	--	---	----------	-----	----------------	-----

Sample Number: 4K04433-52	Site: BAD-2FL-S-Rm 35	Sample ID: First 052
Collector: CMP	Collect Date: 11/16/2024 8:56 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

### Metals

Lead	18.0	µg/L	EPA 200.8	1.00		1	11/25/24	RBP	11/26/24 21:06	RBP
------	------	------	-----------	------	--	---	----------	-----	----------------	-----

Sample Number: 4K04433-53	Site: BAD-2FL-S-Rm 36	Sample ID: First 053
Collector: CMP	Collect Date: 11/16/2024 8:58 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

### Metals

Lead	6.52	µg/L	EPA 200.8	1.00		1	11/25/24	RBP	11/26/24 21:08	RBP
------	------	------	-----------	------	--	---	----------	-----	----------------	-----

Sample Number: 4K04433-54	Site: BRB-1FL-POE-Boiler Room-F	Sample ID: Flush 054
Collector: CMP	Collect Date: 11/16/2024 9:10 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

### Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00		1	11/25/24	RBP	11/26/24 21:10	RBP
------	--------	------	-----------	------	--	---	----------	-----	----------------	-----

Report Generated On: 12/06/2024 3:53 pm 4K04433  
 STL\_Results Revision #3.0 Effective: 05/29/2024





# SUBURBAN TESTING LABS

Sample Number: 4K04433-55      Site: BRB-1FL-FP-Special Services      Sample ID: First 055  
 Collector: CMP      Collect Date: 11/16/2024 9:14 am      Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

### Metals

Lead      2.56      µg/L      EPA 200.8      1.00      1      11/25/24      RBP      11/26/24 21:17      RBP

Sample Number: 4K04433-56      Site: BRB-1FL-FP-Kitchen      Sample ID: First 056  
 Collector: CMP      Collect Date: 11/16/2024 9:16 am      Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

### Metals

Lead      1.32      µg/L      EPA 200.8      1.00      1      11/25/24      RBP      11/26/24 21:19      RBP

Sample Number: 4K04433-57      Site: BRB-1FL-FS-Faculty 156      Sample ID: First 057  
 Collector: CMP      Collect Date: 11/16/2024 9:18 am      Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

### Metals

Lead      1.02      µg/L      EPA 200.8      1.00      1      11/25/24      RBP      11/26/24 21:21      RBP

Sample Number: 4K04433-58      Site: BRB-1FL-DW-O/S Rm 153      Sample ID: First 058  
 Collector: CMP      Collect Date: 11/16/2024 9:20 am      Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

### Metals

Lead      1.74      µg/L      EPA 200.8      1.00      1      11/25/24      RBP      11/26/24 21:23      RBP

Sample Number: 4K04433-59      Site: BRB-1FL-WC-Hall O/S Special Services      Sample ID: First 059  
 Collector: CMP      Collect Date: 11/16/2024 9:22 am      Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

### Metals

Lead      < 1.00      µg/L      EPA 200.8      1.00      1      11/29/24      RPV      12/02/24 17:41      RPV

Sample Number: 4K04433-60      Site: BRB-1FL-BF-Hall O/S Special Services-      Sample ID: First 060  
 Collector: CMP      Collect Date: 11/16/2024 9:24 am      Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

### Metals

Lead      < 1.00      µg/L      EPA 200.8      1.00      1      11/29/24      RPV      12/02/24 17:45      RPV

Sample Number: 4K04433-61      Site: BRB-1FL-WC-Hall O/S 119 Left      Sample ID: First 061  
 Collector: CMP      Collect Date: 11/16/2024 9:26 am      Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

### Metals

Lead      < 1.00      µg/L      EPA 200.8      1.00      1      11/29/24      RPV      12/02/24 17:48      RPV

Report Generated On: 12/06/2024 3:53 pm      4K04433  
 STL\_Results      Revision #3.0      Effective: 05/29/2024





# SUBURBAN TESTING LABS

Sample Number: 4K04433-62	Site: BRB-1FL-DW-Hall O/S Nurse-L	Sample ID: First 062
Collector: CMP	Collect Date: 11/16/2024 9:28 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

### Metals

Lead	2.33	µg/L	EPA 200.8	1.00		1	11/29/24	MKS	12/02/24 18:32	MKS
------	------	------	-----------	------	--	---	----------	-----	----------------	-----

Sample Number: 4K04433-63	Site: BRB-1FL-BF-Hall O/S Nurse-R	Sample ID: First 063
Collector: CMP	Collect Date: 11/16/2024 9:30 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

### Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00		1	11/29/24	MKS	12/02/24 18:34	MKS
------	--------	------	-----------	------	--	---	----------	-----	----------------	-----

Sample Number: 4K04433-64	Site: BRB-1FL-WC-Hall O/S Nurse-R	Sample ID: First 064
Collector: CMP	Collect Date: 11/16/2024 9:32 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

### Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00		1	11/29/24	MKS	12/02/24 18:37	MKS
------	--------	------	-----------	------	--	---	----------	-----	----------------	-----

Sample Number: 4K04433-65	Site: BRB-1FL-NS-Nurse	Sample ID: First 065
Collector: CMP	Collect Date: 11/16/2024 9:34 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

### Metals

Lead	1.45	µg/L	EPA 200.8	1.00		1	11/29/24	MKS	12/02/24 18:39	MKS
------	------	------	-----------	------	--	---	----------	-----	----------------	-----

Sample Number: 4K04433-66	Site: BRB-1FL-WC-Hall O/S Gym-L	Sample ID: First 066
Collector: CMP	Collect Date: 11/16/2024 9:36 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

### Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00		1	11/29/24	MKS	12/02/24 18:41	MKS
------	--------	------	-----------	------	--	---	----------	-----	----------------	-----

Sample Number: 4K04433-67	Site: BRB-1FL-BF-Hall O/S Gym-L	Sample ID: First 067
Collector: CMP	Collect Date: 11/16/2024 9:38 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----	----	-----------	----	---------------	----

### Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00		1	11/27/24	MKS	11/29/24 12:19	MKS
------	--------	------	-----------	------	--	---	----------	-----	----------------	-----

Report Generated On: 12/06/2024 3:53 pm 4K04433  
 STL\_Results Revision #3.0 Effective: 05/29/2024





Sample Number: 4K04433-68	Site: Field Blank	Sample ID: First 068
Collector: CMP	Collect Date: 11/16/2024 9:40 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MRL	MDL	DF	Prep Date	By	Analysis Date	By
<u>Metals</u>										
Lead	< 1.00	µg/L	EPA 200.8	1.00		1	11/27/24	MKS	11/29/24 14:13	MKS

**Sample Receipt Conditions:**

All samples met the sample receipt requirements for the relevant analyses.

The test *pH, Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.

\**pH, Final* for ASTM leachate is performed by method SM 4500-H-B.

All results meet the requirements of STL's NELAP Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.


Results are considered Preliminary unless report is signed by authorized representative of STL.

**Reviewed and Released By:**

Lauren Ulle  
Project Manager I

Report Generated On: 12/06/2024 3:53 pm 4K04433  
STL\_Results Revision #3.0 Effective: 05/29/2024





4K04433  
Lauren Ulle



### Chain of Custody Record

1037F MacArthur Road, Reading, PA 19605  
610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.com

TAT (Check One)  Standard  24hr  48hr  72hr  Other

Client Name: <b>Westchester Environmental LLC.</b>				Project Name: <b>Butler SD</b>			
Address: <b>1248 Wrights Lane</b>		Phone: <b>610-431-7545</b>		Address: <b>High School, Decker, &amp; Butler</b>			
<b>West Chester, PA 19380</b>		Email: <b>cpiccininni@westchesterenvironmental.com</b>		<b>38 Bartholdi Ave, Butler, NJ 07405</b>			
Contact Name: <b>Chris Piccininni</b>				Payment / P.O. Info:			

Comments:

Flush / First Draw	Location Code	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type	Preservative	Sample Description / Site ID
Flush	BHS-LL-SPOE-Boys Rm near 118	11/20/24	07:00 AM	CMP	001	Pb EPA 200.8	1	PW	G	P	H	Boys Rm near 118
First	BHS-ML-WC-Hall o/s attendance	11/20/24	07:04 AM	CMP	002	Pb EPA 200.8	1	PW	G	P	H	Hall o/s attendance
First	BHS-ML-BF-Hall o/s attendance	11/20/24	07:06 AM	CMP	003	Pb EPA 200.8	1	PW	G	P	H	Hall o/s attendance
First	BHS-ML-WC-Hall o/s 210	11/20/24	07:08 AM	CMP	004	Pb EPA 200.8	1	PW	G	P	H	Hall o/s 210
First	BHS-TL-FS-Faculty Room	11/20/24	07:10 AM	CMP	005	Pb EPA 200.8	1	PW	G	P	H	Faculty Room
First	BHS-TL-BF-O/S Faculty Room	11/20/24	07:12 AM	CMP	006	Pb EPA 200.8	1	PW	G	P	H	o/s Faculty Room
First	BHS-TL-WC-O/S Faculty Room	11/20/24	07:14 AM	CMP	007	Pb EPA 200.8	1	PW	G	P	H	o/s Faculty Room
Flush	Art Bldg-LL-SPOE- Boiler Room	11/20/24	07:16 AM	CMP	008	Pb EPA 200.8	1	PW	G	P	H	Boiler Room
First	Art Bldg-ML-NS-Nurse	11/20/24	07:20 AM	CMP	009	Pb EPA 200.8	1	PW	G	P	H	Nurse
First	Art Bldg-ML-NS-Nurse Patient Rm	11/20/24	07:22 AM	CMP	010	Pb EPA 200.8	1	PW	G	P	H	Nurse Patient Rm

Relinquished by:

*CP*

Received By:

*Jahanna Foye*

Relinquished by:

*LA*

Received in Lab By:

*John Glick*

*10*

Date: *11/20/24*

Time: *12:30 PM*

Date: *11/20/24* Temp °C:

Time: *11:19* Acceptable Y / N

Date: *11/20/24* Temp °C:

Time: *1:55* Acceptable Y / N


Date: *11/20/24* Temp °C: *20.7*

Time: *1:53* Acceptable  Y  N

*No ICE*

Sample Conditions	Matrix Key	Bottle Type Key
Submitted w/ COC <input checked="" type="radio"/> Y <input type="radio"/> N	NPW = Non-Potable Water	P = Plastic
Number of containers match number on <input checked="" type="radio"/> Y <input type="radio"/> N	Solid = Raw Sludge, Dewatered Sludge, soil, etc. (reported as mg/l)	G = Glass
All containers intact <input checked="" type="radio"/> Y <input type="radio"/> N	PW = Potable Water (not for SWDA compliance)	O = Other
Tests within holding times <input checked="" type="radio"/> Y <input type="radio"/> N	SWDA = Safe Drinking Water Act Potable Sample	<b>Preservative Key</b>
40 ml VOA vials free of headspace? <input checked="" type="radio"/> Y <input type="radio"/> N	<b>Sample Type Key</b>	H = Sodium Thiosulphate
	G = Grab	A = Ascorbic Acid
	8 HC = 8 Hour Composite	H = HNO3
	24 HC = 24 Hour Composite	C = HCl
		H2SO4
		O = Other
		None Required





4K04433  
Lauren Ulle



TESTING LABS

### Chain of Custody Record

TAT (Check One) Standard 24hr 48hr 72hr Other

1037F MacArthur Road, Reading, PA 19605  
610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.com

Client Name:	Westchester Environmental LLC.			Project Name:	Butler SD
Address:	1248 Wrights Lane	Phone:	610-431-7545	Address:	High School, Decker, & Butler
	West Chester, PA 19380	Email:	cpiccininni@westchesterenvironmental.com		38 Bartholdi Ave, Butler, NJ 07405
Contact Name:	Chris Piccininni			Payment / P.O. Info:	

Comments:

Flush / First Draw	Location Code	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types*	Bottle Type	Preservative	Sample Description / Site ID
First	Art Bldg-ML-S-Sky lands Rm	11/20/24	07:24 AM	CMP	011	Pb EPA 200.8	1	PW	G	P	H	Sky lands Rm
First	Art Bldg-ML-IM-Trainers Rm	11/20/24	07:26 AM	CMP	012	Pb EPA 200.8	1	PW	G	P	H	Trainers Rm
First	Art Bldg-ML-S-Trainers Rm	11/20/24	07:28 AM	CMP	013	Pb EPA 200.8	1	PW	G	P	H	Trainers Rm
First	Art Bldg-ML-BF-Hall o/s Weigh Rm	11/20/24	07:30 AM	CMP	014	Pb EPA 200.8	1	PW	G	P	H	Hall o/s Weigh Rm
First	Art Bldg-ML-WC-Cafeteria Left	11/20/24	07:32 AM	CMP	015	Pb EPA 200.8	1	PW	G	P	H	Cafeteria Left
First	Art Bldg-ML-BF-Cafeteria Left	11/20/24	07:34 AM	CMP	016	Pb EPA 200.8	1	PW	G	P	H	Cafeteria Left
First	Art Bldg-ML-WC-Cafeteria Right	11/20/24	07:36 AM	CMP	017	Pb EPA 200.8	1	PW	G	P	H	Cafeteria Right
First	Art Bldg-ML-WC-Boys Locker Rm	11/20/24	07:38 AM	CMP	018	Pb EPA 200.8	1	PW	G	P	H	Boys Locker Rm
First	Art Bldg-ML-BF-BOYS LOCKER RM	11/20/24	07:40 AM	CMP	019	Pb EPA 200.8	1	PW	G	P	H	BOYS LOCKER RM
First	Art Bldg-ML-WC-Girls Locker Rm	11/20/24	07:42 AM	CMP	020	Pb EPA 200.8	1	PW	G	P	H	Girls Locker Rm

Relinquished by:

*CP*

Received By:

*Lauren Ulle*

Relinquished by:

*LA*

Received in Lab By:

*LA*

*(10)*

Date: 11/19/24

Time: 12:30 PM

Date: 11/20/24 Temp °C:

Time: 11:19 Acceptable Y / N


Date: 11/20/24 Temp °C:

Time: 1:35 Acceptable Y / N

Date: 11/20/24 Temp °C: 20.7

Time: 1:53 Acceptable Y / N  
No LCE

Sample Conditions	Matrix Key	Bottle Type Key
Submitted w/ COC <input checked="" type="checkbox"/> Y / N	NPW = Non-Potable Water	P = Plastic
Number of containers match number on COC? <input checked="" type="checkbox"/> Y / N	Solid = Raw Sludge, Dewatered Sludge, soil, etc (reported as mg/l) PW = Potable Water (not for SWDA compliance) SWDA = Safe Drinking Water Act Potable Sample	G = Glass O = Other
All containers intact <input checked="" type="checkbox"/> Y / N	Sample Type Key: G = Grab, 8 HC = 8 Hour Composite, 24 HC = 24 Hour Composite	Preservative Key: H = Sodium Thiosulphate, A = Ascorbic Acid, H = HNO3, C = HCl, S = H2SO4, OH = NaOH, O = Other, None Required
Tests within holding times <input checked="" type="checkbox"/> Y / N	SWDA Sample Type: D = Distribution, E = Entry Point, R = Raw, C = Check, S = Special, M = Maximum Residence	
40 ml. VOA vials free of headspace? <input checked="" type="checkbox"/> Y / N		



4K04433  
Lauren Ulle



### Chain of Custody Record

TAT (Check One) Standard 24hr 48hr 72hr Other

1037F MacArthur Road, Reading, PA 19605  
610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.com

Client Name:	Westchester Environmental LLC.			Project Name:	Butler SD
Address:	1248 Wrights Lane	Phone:	610-431-7545	Address:	High School, Decker, & Butler
	West Chester, PA 19380	Email:	cpiccininni@westchesterenvironmental.com		38 Bartholdi Ave, Butler, NJ 07405
Contact Name:	Chris Piccininni			Payment / P.O. Info:	

Comments:

Flush / First Draw	Location Code	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type	Preservative	Sample Description / Site ID
First	Art Bldg-ML-BF-Girls Locker Rm	11/20/24	07:44 AM	CMP	021	Pb EPA 200.8	1	PW	G	P	H	Girls Locker Rm
First	Art Bldg-ML-WC- O/S Girls Locker Rm	11/20/24	07:46 AM	CMP	022	Pb EPA 200.8	1	PW	G	P	H	O/S Girls Locker Rm
First	Art Bldg-ML-FP-Kitchen 2	11/20/24	07:48 AM	CMP	023	Pb EPA 200.8	1	PW	G	P	H	Kitchen 2
First	Art Bldg-ML-FP-Kitchen 3	11/20/24	07:50 AM	CMP	024	Pb EPA 200.8	1	PW	G	P	H	Kitchen 3
First	Art Bldg-ML-FP-Kitchen 5	11/20/24	07:52 AM	CMP	025	Pb EPA 200.8	1	PW	G	P	H	Kitchen 5
First	Art Bldg-LL-WC-Bsmt Locker RM	11/20/24	07:54 AM	CMP	026	Pb EPA 200.8	1	PW	G	P	H	Bsmt Locker RM
First	Art Bldg-TL-WC-Hall o/s Rm 335 Left	11/20/24	07:56 AM	CMP	027	Pb EPA 200.8	1	PW	G	P	H	Hall o/s Rm 335 Left
First	Art Bldg-TL-WC-Hall o/s Rm 335 Right	11/20/24	07:58 AM	CMP	028	Pb EPA 200.8	1	PW	G	P	H	Hall o/s Rm 335 Right
First	Art Bldg-TL-WC-Hall O/s Rm 336	11/20/24	08:00 AM	CMP	029	Pb EPA 200.8	1	PW	G	P	H	Hall O/s Rm 336
First	Art Bldg-TL-BF-Hall O/s Rm 336	11/20/24	08:02 AM	CMP	030	Pb EPA 200.8	1	PW	G	P	H	Hall O/s Rm 336

Relinquished by:

*[Signature]*

Received By:

*[Signature]*

Relinquished by:

*[Signature]*

Received in Lab By:

*[Signature]* 10

Date: 11/19/24

Time: 12:30 PM

Date: 11/20/24 Temp °C:

Time: 1114 Acceptable Y/N

Date: 11/20/24 Temp °C:

Time: 1355 Acceptable Y/N


Date: 11/20/24 Temp °C: 20.7

Time: 1536 Acceptable Y/N

No Ice

Sample Conditions	Matrix Key	Bottle Type Key
Submitted w/ COC <input checked="" type="checkbox"/> Y/N	NPW = Non-Potable Water	P = Plastic
Number of containers match number on <input checked="" type="checkbox"/> Y/N	Solid = Raw Sludge, Dewatered Sludge, soil, etc. (reported as mg/l)	G = Glass
All containers intact <input checked="" type="checkbox"/> Y/N	PW = Potable Water (not for SWDA compliance)	O = Other
Tests within holding times <input checked="" type="checkbox"/> Y/N	SWDA = Safe Drinking Water Act Potable Sample	<b>Preservative Key</b>
40 ml. VOA vials free of headspace? <input checked="" type="checkbox"/> Y/N	<b>Sample Type Key</b>	H = Sodium Thiosulphate
	G = Grab	A = Ascorbic Acid
	B HC = 8 Hour Composite	H = HNO3
	R = Raw	S = H2SO4
	C = Check	OH = NaOH
	S = Special	None Required
	M = Maximum Residence	NA =





4K04433  
Lauren Ulle



### Chain of Custody Record

TAT (Check One) Standard 24hr 48hr 72hr Other

1037F MacArthur Road, Reading, PA 19605  
610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.com

Client Name:	<b>Westchester Environmental LLC.</b>			Project Name:	Butler SD
Address:	<b>1248 Wrights Lane</b>	Phone:	<b>610-431-7545</b>	Address:	High School, Decker, & Butler
	<b>West Chester, PA 19380</b>	Email:	cpiccininni@westchesterenvironmental.com	38 Bartholdi Ave, Butler, NJ 07405	
Contact Name:	<b>Chris Piccininni</b>			Payment / P.O. Info:	

Comments:

Flush / First Draw	Location Code	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type	Preservative	Sample Description / Site ID
First	BAD-1FL-FP1-Kitchen	11/20/24	08:34 AM	CMP	041	Pb EPA 200.8	1	PW	G	P	H	Kitchen
First	BAD-1FL-KO-Kitchen	11/20/24	08:36 AM	CMP	042	Pb EPA 200.8	1	PW	G	P	H	Kitchen
First	BAD-1FL-WC-Hall o/s Kitchen	11/20/24	08:38 AM	CMP	043	Pb EPA 200.8	1	PW	G	P	H	Hall o/s Kitchen
First	BAD-1FL-BF-Hall o/s Kitchen	11/20/24	08:40 AM	CMP	044	Pb EPA 200.8	1	PW	G	P	H	Hall o/s Kitchen
First	BAD-1FL-NS- Nurse	11/20/24	08:42 AM	CMP	045	Pb EPA 200.8	1	PW	G	P	H	Nurse
First	BAD-1FL-FS-Faculty Rm	11/20/24	08:44 AM	CMP	046	Pb EPA 200.8	1	PW	G	P	H	Faculty Rm
First	BAD-1FL-WC-Hall o/s Rm 28	11/20/24	08:46 AM	CMP	047	Pb EPA 200.8	1	PW	G	P	H	Hall o/s Rm 28
First	BAD-2FL-BF-Hall o/s Rm 28	11/20/24	08:48 AM	CMP	048	Pb EPA 200.8	1	PW	G	P	H	Hall o/s Rm 28
First	BAD-2FL-WC-Hall o/s Rm 35	11/20/24	08:50 AM	CMP	049	Pb EPA 200.8	1	PW	G	P	H	Hall o/s Rm 35
First	BAD--BF-Hall o/s Rm 35	11/20/24	08:52 AM	CMP	050	Pb EPA 200.8	1	PW	G	P	H	Hall o/s Rm 35

Relinquished by:

Date: 11/19/24

Time: 12:30 PM

Received By:

Date: 11/20/24

Temp °C: Acceptable Y/N

Relinquished by:

Date: 11/20/24

Temp °C: Acceptable Y/N

Received in Lab By:


Date: 11/20/24

Temp °C: 20.7

Time: 1:53 PM Acceptable Y/N

NO ILE

Sample Conditions	Matrix Key	Bottle Type Key	Reporting options
Submitted w/ COC <input checked="" type="checkbox"/> Y/N	NPW = Non-Potable Water	P = Plastic G = Glass O = Other	<input type="checkbox"/> SWDA Reporting <input type="checkbox"/> PW SID
Number of containers match number on COC? <input checked="" type="checkbox"/> Y/N	Solid = Raw Sludge, Dewatered Sludge, soil, etc. (reported as mg/l) PW = Potable Water (not for SWDA compliance) SWDA = Safe Drinking Water Act Potable Sample	<b>Preservative Key</b> H = Sodium Thiosulphate A = Ascorbic Acid H = HNO3 C = HCl S = OH = NaOH None Required	<input type="checkbox"/> Fax <input type="checkbox"/> Email
All containers intact <input checked="" type="checkbox"/> Y/N	<b>Sample Type Key</b> G = Grab 8 HC = 8 Hour Composite E = Entry Point R = Raw C = Check S = Special M = Maximum Composite	<b>SWDA Sample Type</b> D = Distribution R = Raw C = Check S = Special M = Maximum Composite Residence	<input type="checkbox"/> Other <input type="checkbox"/> Return a copy of this form with Report
Tests within holding times <input checked="" type="checkbox"/> Y/N	40 ml. VOA vials free of headspace? <input checked="" type="checkbox"/> Y/N		



4K04433  
Lauren Ulle



### Chain of Custody Record

1037F MacArthur Road, Reading, PA 19605  
610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.com

TAT (Check One) Standard 24hr 48hr 72hr Other

Client Name:	Westchester Environmental LLC.			Project Name:	Butler SD
Address:	1248 Wrights Lane	Phone:	610-431-7545	Address:	High School, Decker, & Butler
	West Chester, PA 19380	Email:	cpiccininni@westchesterenvironmental.com		38 Bartholdi Ave, Butler, NJ 07405
Contact Name:	Chris Piccininni			Payment / P.O. Info:	

Comments:

Flush / First Draw	Location Code	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type	Preservative	Sample Description / Site ID
First	BAD-FS-Faculty Rm 36	11/20/24	08:54 AM	CMP	051	Pb EPA 200.8	1	PW	G	P	H	Faculty Rm 36
First	BAD-2FL-S-Rm 35	11/20/24	08:56 AM	CMP	052	Pb EPA 200.8	1	PW	G	P	H	Rm 35
First	BAD-2FL-S-Rm 36	11/20/24	08:58 AM	CMP	053	Pb EPA 200.8	1	PW	G	P	H	Rm 36
Flush	BRB-1FL-POE-Boiler Room	11/20/24	09:10 AM	CMP	054	Pb EPA 200.8	1	PW	G	P	H	Boiler Room
First	BRB-1FL-FP-Special Services	11/20/24	09:14 AM	CMP	055	Pb EPA 200.8	1	PW	G	P	H	Special Services
First	BRB-1FL-FP-Kitchen	11/20/24	09:16 AM	CMP	056	Pb EPA 200.8	1	PW	G	P	H	Kitchen
First	BRB-1FL-FS-Faculty 156	11/20/24	09:18 AM	CMP	057	Pb EPA 200.8	1	PW	G	P	H	Faculty 156
First	BRB-1FL-DW-o/s Rm 153	11/20/24	09:20 AM	CMP	058	Pb EPA 200.8	1	PW	G	P	H	o/s Rm 153
First	BRB-1FL-WC-Hall o/s Special Services-L	11/20/24	09:22 AM	CMP	059	Pb EPA 200.8	1	PW	G	P	H	Hall o/s Special Services-L
First	BRB-1FL-BF-Hall o/s Special Services-R	11/20/24	09:24 AM	CMP	060	Pb EPA 200.8	1	PW	G	P	H	Hall o/s Special Services-R

Relinquished by:

*CP*

Date: 11/19/24

Time: 12:30 PM

Received By:

*Lauren Ulle*

Date: 11/20/24 Temp °C:

Time: 11:49 Acceptable Y/N

Relinquished by:

*Lauren Ulle*

Date: 11/20/24 Temp °C:

Time: 1:55 Acceptable Y/N


Received in Lab By:

*Lauren Ulle*

Date: 11/20/24 Temp °C: 20.7

Time: 1:56 Acceptable Y/N  
NO ICE

Sample Conditions	Matrix Key	Bottle Type Key
Submitted w/ COC <input checked="" type="checkbox"/> Y/N	NPW = Non-Potable Water	P = Plastic
Number of containers match number on <input checked="" type="checkbox"/> Y/N	Solid = Raw Sludge, Dewatered Sludge, soil, etc. (reported as mg/l)	G = Glass
All containers intact <input checked="" type="checkbox"/> Y/N	PW = Potable Water (not for SWDA compliance)	O = Other
Tests within holding times <input checked="" type="checkbox"/> Y/N	SWDA = Safe Drinking Water Act Potable Sample	<b>Preservative Key</b>
40 ml. VOA vials free of headspace? <input checked="" type="checkbox"/> Y/N	<b>Sample Type Key</b>	H = Sodium Thiosulphate Acid
	G = Grab	A = Ascorbic Acid
	8 HC = 8 Hour Composite	H = HNO3
	R = Raw	C = HCl
	C = Check	S =
	S = Special	H2SO4
	M = Maximum Residence	OH = NaOH
		None Required



4K04433  
Lauren Ulle



### Chain of Custody Record

IAI (Check One) Standard 24hr 48hr 72hr Other

1037F MacArthur Road, Reading, PA 19605  
610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.com

Client Name:	<b>Westchester Environmental LLC.</b>		Project Name:	Butler SD
Address:	<b>1248 Wrights Lane</b>	Phone:	610-431-7545	
	<b>West Chester, PA 19380</b>	Email:	cpiccininni@westchesterenvironmental.com	
Contact Name:	<b>Chris Piccininni</b>	Payment / P.O. Info:	High School, Decker, & Butler 38 Bartholdi Ave, Butler, NJ 07405	

Comments:

Flush / First Draw	Location Code	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type	Preservative	Sample Description / Site ID
First	BRB-1FL-WC-Hall o/s 119 Left	11/20/24	09:26 AM	CMP	61	Pb EPA 200.8	1	PW	G	P	H	Hall o/s 119 Left
First	BRB-1FL-DW-Hall o/s Nurse-L	11/20/24	09:28 AM	CMP	62	Pb EPA 200.8	1	PW	G	P	H	Hall o/s Nurse-L
First	BRB-1FL-BF-Hall o/s Nurse-R	11/20/24	09:30 AM	CMP	63	Pb EPA 200.8	1	PW	G	P	H	Hall o/s Nurse-R
First	BRB-1FL-WC-Hall o/s Nurse-R	11/20/24	09:32 AM	CMP	64	Pb EPA 200.8	1	PW	G	P	H	Hall o/s Nurse-R
First	BRB-1FL-NS-Nurse	11/20/24	09:34 AM	CMP	65	Pb EPA 200.8	1	PW	G	P	H	Nurse
First	BRB-1FL-WC-Hall o/s Gym-L	11/20/24	09:36 AM	CMP	66	Pb EPA 200.8	1	PW	G	P	H	Hall o/s Gym-L
First	BRB-1FL-BF-Hall o/s Gym-L	11/20/24	09:38 AM	CMP	67	Pb EPA 200.8	1	PW	G	P	H	Hall o/s Gym-L
First	Field Blank	11/20/24	09:40 AM	CMP	68	Pb EPA 200.8	1	PW	G	P	H	Field Blank

Relinquished by:

Date: 11/19/24  
Time: 12:30 PM

Received By:

Date: 11/20/24 Temp °C:  
Time: 1119 Acceptable Y / N

Relinquished by:

Date: 11/20/24 Temp °C:  
Time: 855 Acceptable Y / N

Received in Lab By:

Date: 11/20/24 Temp °C: 20.7  
Time: 1536 Acceptable Y/N  
NO ICE

Sample Conditions	Matrix Key	Bottle Type Key
Submitted w/ COC <input checked="" type="checkbox"/> Y/N	NPW = Non-Potable Water	P = Plastic
Number of containers match number on COC? <input checked="" type="checkbox"/> Y/N	Solid = Raw Sludge, Dewatered Sludge, soil, etc. (reported as mg/l)	G = Glass
All containers intact <input checked="" type="checkbox"/> Y/N	PW = Potable Water (not for SWDA compliance)	O = Other
Tests within holding times <input checked="" type="checkbox"/> Y/N	SWDA = Safe Drinking Water Act Potable Sample	<b>Preservative Key</b>
40 ml. VOA vials free of headspace? <input checked="" type="checkbox"/> Y/N	<b>Sample Type Key</b>	H = Sodium Thiosulphate
	G = Grab	Acid
	8 HC = 8 Hour Composite	A = Ascorbic
	24 HC = 24 Hour Composite	H = HNO3
		C = HCl
		S =
		H2SO4
		OH = NaOH
		O = Other
		None Required
		NA =

O = pH < 2  
(68) 250 mL P+ HNO3  
VMS2 11-20-24



4K04433  
Lauren Ulle

COC Pg 1



**Chain of Custody Record**

TAT (Check One)    Standard    24hr    48hr    72hr    Other

1037F MacArthur Road, Reading, PA 19605  
610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.com

Client Name:	<b>Westchester Environmental LLC.</b>			Project Name:	Butler SD
Address:	<b>1248 Wrights Lane</b>	Phone:	<b>610-431-7545</b>	Address:	High School, Decker, & Butler
	<b>West Chester, PA 19380</b>	Email:	cpiccininni@westchesterenvironmental.com		38 Bartholdi Ave, Butler, NJ 07405
Contact Name:	<b>Chris Piccininni</b>			Payment / P.O. Info:	

Comments:

Flush / First Draw	Location Code	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type	Preservative	Sample Description / Site ID
Flush	BHS-LL-SPOE-Boys Rm near 118	11/20/24	07:00 AM	CMP	001	Pb EPA 200.8	1	PW	G	P	H	Boys Rm near 118
First	BHS-ML-WC-Hall o/s attendance	11/20/24	07:04 AM	CMP	002	Pb EPA 200.8	1	PW	G	P	H	Hall o/s attendance
First	BHS-ML-BF-Hall o/s attendance	11/20/24	07:06 AM	CMP	003	Pb EPA 200.8	1	PW	G	P	H	Hall o/s attendance
First	BHS-ML-WC-Hall o/s 210	11/20/24	07:08 AM	CMP	004	Pb EPA 200.8	1	PW	G	P	H	Hall o/s 210
First	BHS-TL-FS-Faculty Room	11/20/24	07:10 AM	CMP	005	Pb EPA 200.8	1	PW	G	P	H	Faculty Room
First	BHS-TL-BF-O/S Faculty Room	11/20/24	07:12 AM	CMP	006	Pb EPA 200.8	1	PW	G	P	H	o/s Faculty Room
First	BHS-TL-WC-O/S Faculty Room	11/20/24	07:14 AM	CMP	007	Pb EPA 200.8	1	PW	G	P	H	o/s Faculty Room
Flush	Art Bldg-LL-SPOE- Boiler Room	11/20/24	07:16 AM	CMP	008	Pb EPA 200.8	1	PW	G	P	H	Boiler Room
First	Art Bldg-ML-NS-Nurse	11/20/24	07:20 AM	CMP	009	Pb EPA 200.8	1	PW	G	P	H	Nurse
First	Art Bldg-ML-NS-Nurse Patient Rm	11/20/24	07:22 AM	CMP	010	Pb EPA 200.8	1	PW	G	P	H	Nurse Patient Rm

Relinquished by: \_\_\_\_\_ Date: \_\_\_\_\_  
 Time: \_\_\_\_\_

Received By: \_\_\_\_\_ Date: \_\_\_\_\_ Temp °C: \_\_\_\_\_  
 Time: Acceptable Y / N

Relinquished by: \_\_\_\_\_ Date: \_\_\_\_\_ Temp °C: \_\_\_\_\_  
 Time: Acceptable Y / N

Received in Lab By: \_\_\_\_\_ Date: \_\_\_\_\_ Temp °C: \_\_\_\_\_  
 Time: Acceptable Y / N

Sample Conditions	Matrix Key	Bottle Type Key
Submitted w/ COC Y / N	NPW = Non-Potable Water Solid = Raw Sludge, Dewatered Sludge, soil, etc. (reported as mg/l)	P = Plastic G = Glass O = Other
Number of containers match number on Y / N	PW = Potable Water (not for SWDA compliance)	<b>Preservative Key</b> H = Sodium
All containers intact Y / N	SWDA = Safe Drinking Water Act Potable Sample	Thiosulphate Acid A = Ascorbic H = HNO3 S = C = HCl OH = NaOH H <sub>2</sub> SO <sub>4</sub> O = Other None Required
Tests within holding times Y / N	<b>Sample Type Key</b> G = Grab 8 HC = 8 Hour Composite 24 HC = 24 Hour Composite	<b>SWDA Sample Type</b> D = Distribution E = Entry Point R = Raw C = Check S = Special M = Maximum Residence
40 ml. VOA vials free of headspace ? Y / N		

11/20/24 Per Chris  
Sampled on  
11/16/24



4K04433  
Lauren Uille

**Chain of Custody Record**

TAT (Check One)    Standard    24hr    48hr    72hr    Other

**TESTING LABS**

1037F MacArthur Road, Reading, PA 19605  
610-375-TEST – Fax: 610-375-4090 – suburbantestinglabs.com

Client Name:	<b>Westchester Environmental LLC.</b>			Project Name:	Butler SD
Address:	<b>1248 Wrights Lane</b>	Phone:	<b>610-431-7545</b>	Address:	High School, Decker, & Butler
	<b>West Chester, PA 19380</b>	Email:	cpiccininni@westchesterenvironmental.com		38 Bartholdi Ave, Butler, NJ 07405
Contact Name:	<b>Chris Piccininni</b>			Payment / P.O. Info:	

Comments:

Flush / First Draw	Location Code	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Type	Bottle Type	Preservative	Sample Description / Site ID
First	Art Bldg-ML-S-Sky lands Rm	11/20/24	07:24 AM	CMP	011	Pb EPA 200.8	1	PW	G	P	H	Sky lands Rm
First	Art Bldg-ML-IM-Trainers Rm	11/20/24	07:26 AM	CMP	012	Pb EPA 200.8	1	PW	G	P	H	Trainers Rm
First	Art Bldg-ML-S-Trainers Rm	11/20/24	07:28 AM	CMP	013	Pb EPA 200.8	1	PW	G	P	H	Trainers Rm
First	Art Bldg-ML-BF-Hall o/s Weigh Rm	11/20/24	07:30 AM	CMP	014	Pb EPA 200.8	1	PW	G	P	H	Hall o/s Weigh Rm
First	Art Bldg-ML-WC-Cafeteria Left	11/20/24	07:32 AM	CMP	015	Pb EPA 200.8	1	PW	G	P	H	Cafeteria Left
First	Art Bldg-ML-BF-Cafeteria Left	11/20/24	07:34 AM	CMP	016	Pb EPA 200.8	1	PW	G	P	H	Cafeteria Left
First	Art Bldg-ML-WC-Cafeteria Right	11/20/24	07:36 AM	CMP	017	Pb EPA 200.8	1	PW	G	P	H	Cafeteria Right
First	Art Bldg-ML-WC-Boys Locker Rm	11/20/24	07:38 AM	CMP	018	Pb EPA 200.8	1	PW	G	P	H	Boys Locker Rm
First	Art Bldg-ML-BF-BOYS LOCKER RM	11/20/24	07:40 AM	CMP	019	Pb EPA 200.8	1	PW	G	P	H	BOYS LOCKER RM
First	Art Bldg-ML-WC-Girls Locker Rm	11/20/24	07:42 AM	CMP	020	Pb EPA 200.8	1	PW	G	P	H	Girls Locker Rm

Relinquished by: \_\_\_\_\_ Date: \_\_\_\_\_  
 Time: \_\_\_\_\_

Received By: \_\_\_\_\_ Date: \_\_\_\_\_ Temp °C: \_\_\_\_\_  
 Time: \_\_\_\_\_ Acceptable Y / N


Relinquished by: \_\_\_\_\_ Date: \_\_\_\_\_ Temp °C: \_\_\_\_\_  
 Time: \_\_\_\_\_ Acceptable Y / N

Received in Lab By: \_\_\_\_\_ Date: \_\_\_\_\_ Temp °C: \_\_\_\_\_  
 Time: \_\_\_\_\_ Acceptable Y / N

Sample Conditions		Matrix Key		Bottle Type Key	
Submitted w/ COC	Y / N	NPW = Non-Potable Water		P = Plastic	
Number of containers match	Y / N	Solid = Raw Sludge, Dewatered Sludge, soil, etc. (reported as mg/l)		G = Glass	
All containers intact	Y / N	PW = Potable Water (not for SWDA compliance)		O = Other	
Tests within holding times	Y / N	SWDA = Safe Drinking Water Act Potable Sample		<b>Preservative Key</b>	
40 ml. VOA vials free of headspace ?	Y / N	<b>Sample Type Key</b>	<b>SWDA Sample Type</b>	H = Sodium Thiosulphate	A = Ascorbic Acid
		G = Grab	D = Distribution	C = HCl	H = HNO3
		8 HC = 8 Hour Composite	E = Entry Point	H <sub>2</sub> SO <sub>4</sub>	S =
			R = Raw	O = Other	OH = NaOH
			C = Check		NA =
			S = Special	None	
			M = Maximum Residence	Required	

11/20/24 Per Chris  
 Sampled on 11/16  
 UAL





4K04433  
Lauren Ulle

### Chain of Custody Record

TAT (Check One)    Standard    24hr    48hr    72hr    Other

#### TESTING LABS

1037F MacArthur Road, Reading, PA 19605  
610-375-TEST - Fax: 610-375-4090 - suburban.testinglabs.com

Client Name:	Westchester Environmental LLC.			Project Name:	Butler SD
Address:	1248 Wrights Lane	Phone:	610-431-7545	Address:	High School, Decker, & Butler
	West Chester, PA 19380	Email:	cpiccininni@westchesterenvironmental.com		38 Bartholdi Ave, Butler, NJ 07405
Contact Name:	Chris Piccininni	Payment / P.O. Info:			

Comments:

Flush / First Draw	Location Code	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type	Preservative	Sample Description / Site ID
First	Art Bldg-ML-BF-Girls Locker Rm	11/20/24	07:44 AM	CMP	021	Pb EPA 200.8	1	PW	G	P	H	Girls Locker Rm
First	Art Bldg-ML-WC- O/S Girls Locker Rm	11/20/24	07:46 AM	CMP	022	Pb EPA 200.8	1	PW	G	P	H	O/S Girls Locker Rm
First	Art Bldg-ML-FP-Kitchen 2	11/20/24	07:48 AM	CMP	023	Pb EPA 200.8	1	PW	G	P	H	Kitchen 2
First	Art Bldg-ML-FP-Kitchen 3	11/20/24	07:50 AM	CMP	024	Pb EPA 200.8	1	PW	G	P	H	Kitchen 3
First	Art Bldg-ML-FP-Kitchen 5	11/20/24	07:52 AM	CMP	025	Pb EPA 200.8	1	PW	G	P	H	Kitchen 5
First	Art Bldg-LL-WC-Bsmt Locker RM	11/20/24	07:54 AM	CMP	026	Pb EPA 200.8	1	PW	G	P	H	Bsmt Locker RM
First	Art Bldg-TL-WC-Hall o/s Rm 335 Left	11/20/24	07:56 AM	CMP	027	Pb EPA 200.8	1	PW	G	P	H	Hall o/s Rm 335 Left
First	Art Bldg-TL-WC-Hall o/s Rm 335 Right	11/20/24	07:58 AM	CMP	028	Pb EPA 200.8	1	PW	G	P	H	Hall o/s Rm 335 Right
First	Art Bldg-TL-WC-Hall O/s Rm 336	11/20/24	08:00 AM	CMP	029	Pb EPA 200.8	1	PW	G	P	H	Hall O/s Rm 336
First	Art Bldg-TL-BF-Hall O/s Rm 336	11/20/24	08:02 AM	CMP	030	Pb EPA 200.8	1	PW	G	P	H	Hall O/s Rm 336

Relinquished by:

Date:

Time:

Received By:

Date:

Temp °C:

Time:

Acceptable Y / N

Relinquished by:

Date:

Temp °C:

Time:

Acceptable Y / N

Received in Lab By:

Date:

Temp °C:

Time:

Acceptable Y / N

Sample Conditions	Matrix Key	Bottle Type Key
Submitted w/ COC Y / N	NPW = Non-Potable Water	P = Plastic
Number of containers match number on Y / N	Solid = Raw Sludge, Dewatered Sludge, soil, etc. (reported as mg/l)	G = Glass
All containers intact Y / N	PW = Potable Water (not for SWDA compliance)	O = Other
Tests within holding times Y / N	SWDA = Safe Drinking Water Act Potable Sample	<b>Preservative Key</b>
40 ml. VOA vials free of headspace ? Y / N	<b>Sample Type Key</b>	H = Sodium Thiosulphate
	G = Grab	Acid
	8 HC = 8 Hour Composite	A = Ascorbic H = HNO3
		C = HCl S =
		H2SO4 OH = NaOH
		O = Other NA =
		None Required
	<b>SWDA Sample Type</b>	
	D = Distribution	
	E = Entry Point	
	R = Raw	
	C = Check	
	S = Special	
	M = Maximum Residence	

11/20/24 Per Chris sampled on 11/14  
LU



4K04433  
Lauren Ulle

### Chain of Custody Record

TAT (Check One)    Standard    24hr    48hr    72hr    Other

TESTING LABS

1037F MacArthur Road, Reading, PA 19605  
610-375-TEST – Fax: 610-375-4090 – suburban testinglabs.com

Client Name:	<b>Westchester Environmental LLC.</b>	Project Name:	Butler SD
Address:	<b>1248 Wrights Lane</b>	Address:	High School, Decker, & Butler
	<b>West Chester, PA 19380</b>		38 Bartholdi Ave, Butler, NJ 07405
Contact Name:	<b>Chris Piccininni</b>	Email:	cpiccininni@westchesterenviromental.com
Comments:		Payment / P.O. Info:	

Flush / First Draw	Location Code	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Type <sup>s</sup>	Bottle Type	Preservative	Sample Description / Site ID
First	Art Bldg-TL-FP-Foods Lab 1	11/20/24	08:04 AM	CMP	031	Pb EPA 200.8	1	PW	G	P	H	Foods Lab 1
First	Art Bldg-TL-FP-Foods Lab 2	11/20/24	08:06 AM	CMP	032	Pb EPA 200.8	1	PW	G	P	H	Foods Lab 2
First	Art Bldg-TL-FP-Foods Lab 3	11/20/24	08:08 AM	CMP	033	Pb EPA 200.8	1	PW	G	P	H	Foods Lab 3
First	Art Bldg-TL-FP-Foods Lab 4	11/20/24	08:10 AM	CMP	034	Pb EPA 200.8	1	PW	G	P	H	Foods Lab 4
First	Art Bldg-TL-FP-Foods Lab 5	11/20/24	08:12 AM	CMP	035	Pb EPA 200.8	1	PW	G	P	H	Foods Lab 5
First	Art Bldg-TL-FP-Foods Lab 6	11/20/24	08:14 AM	CMP	036	Pb EPA 200.8	1	PW	G	P	H	Foods Lab 6
First	Art Bldg-TL-WC-Hall o/s BOE Offices	11/20/24	08:16 AM	CMP	037	Pb EPA 200.8	1	PW	G	P	H	Hall o/s BOE Offices
First	Art Bldg-TL-BF-Hall o/s BOE Office	11/20/24	08:18 AM	CMP	038	Pb EPA 200.8	1	PW	G	P	H	Hall o/s BOE Office
First	Art Bldg-TL-S-BOE Office Rm 13	11/20/24	08:20 AM	CMP	039	Pb EPA 200.8	1	PW	G	P	H	BOE Office Rm 13
Flush	BAD-1FL-SPOE-Kitchen	11/20/24	08:30 AM	CMP	040	Pb EPA 200.8	1	PW	G	P	H	Kitchen

Relinquished by: \_\_\_\_\_ Date: \_\_\_\_\_  
 Received By: \_\_\_\_\_ Date: \_\_\_\_\_ Temp °C: \_\_\_\_\_  
 Relinquished by: \_\_\_\_\_ Date: \_\_\_\_\_ Temp °C: \_\_\_\_\_  
 Received in Lab By: \_\_\_\_\_ Date: \_\_\_\_\_ Temp °C: \_\_\_\_\_

Sample Conditions	Matrix Key	Bottle Type Key
Submitted w/ COC Y / N	NPW = Non-Potable Water	P = Plastic
number of containers match number on COC? Y / N	Solid = Raw Sludge, Dewatered Sludge, soil, etc. (reported as mg/l)	G = Glass
All containers intact Y / N	PW = Potable Water (not for SWDA compliance)	O = Other
Tests within holding times Y / N	SWDA = Safe Drinking Water Act Potable Sample	<b>Preservative Key</b>
40 ml. VOA vials free of headspace? Y / N	<b>Sample Type Key</b>	H = Sodium
	G = Grab	Thiosulphate Acid
	8 HC = 8 Hour	A = Ascorbic
	Composite	H = HNO3
	Check	C = HCl
	Special	S =
	Maximum	H2SO4
	Residence	O = Other
		None
		OH = NaOH
		NA = Required

11/20/24 Per Chris  
sampled on 11/14  
UAN



4K04433  
Lauren Uille

**Chain of Custody Record**

TAT (Check One)    Standard    24hr    48hr    72hr    Other

**TESTING LABS**

1037F MacArthur Road, Reading, PA 19605  
610-375-TEST – Fax: 610-375-4090 – suburban testinglabs.com

Client Name:	<b>Westchester Environmental LLC.</b>			Project Name:	Butler SD
Address:	<b>1248 Wrights Lane</b>	Phone:	<b>610-431-7545</b>	Address:	High School, Decker, & Butler
	<b>West Chester, PA 19380</b>	Email:	cpiccininni@westchesterenviromental.com		38 Bartholdi Ave, Butler, NJ 07405
Contact Name:	<b>Chris Piccininni</b>			Payment / P.O. Info:	

Comments:

Flush / First Draw	Location Code	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type	Preservative	Sample Description / Site ID
First	BAD-1FL-FP1-Kitchen	11/20/24	08:34 AM	CMP	041	Pb EPA 200.8	1	PW	G	P	H	Kitchen
First	BAD-1FL-KO-Kitchen	11/20/24	08:36 AM	CMP	042	Pb EPA 200.8	1	PW	G	P	H	Kitchen
First	BAD-1FL-WC-Hall o/s Kitchen	11/20/24	08:38 AM	CMP	043	Pb EPA 200.8	1	PW	G	P	H	Hall o/s Kitchen
First	BAD-1FL-BF-Hall o/s Kitchen	11/20/24	08:40 AM	CMP	044	Pb EPA 200.8	1	PW	G	P	H	Hall o/s Kitchen
First	BAD-1FL-NS- Nurse	11/20/24	08:42 AM	CMP	045	Pb EPA 200.8	1	PW	G	P	H	Nurse
First	BAD-1FL-FS-Faculty Rm	11/20/24	08:44 AM	CMP	046	Pb EPA 200.8	1	PW	G	P	H	Faculty Rm
First	BAD-1FL-WC-Hall o/s Rm 28	11/20/24	08:46 AM	CMP	047	Pb EPA 200.8	1	PW	G	P	H	Hall o/s Rm 28
First	BAD-2FL-BF-Hall o/s Rm 28	11/20/24	08:48 AM	CMP	048	Pb EPA 200.8	1	PW	G	P	H	Hall o/s Rm 28
First	BAD-2FL-WC-Hall o/s Rm 35	11/20/24	08:50 AM	CMP	049	Pb EPA 200.8	1	PW	G	P	H	Hall o/s Rm 35
First	BAD-BF-Hall o/s Rm 35	11/20/24	08:52 AM	CMP	050	Pb EPA 200.8	1	PW	G	P	H	Hall o/s Rm 35

Relinquished by:

Date:

Time:

Received By:

Date:

Temp °C:

Time:

Acceptable Y / N

Relinquished by:

Date:

Temp °C:

Time:

Acceptable Y / N

Received in Lab By:

Date:

Temp °C:

Time:

Acceptable Y / N

Sample Conditions		Matrix Key		Bottle Type Key		Reporting options	
Submitted w/ COC	Y / N	NPW = Non-Potable Water		P = Plastic		<input type="checkbox"/>	SWDA Reporting
Number of containers match	Y / N	Solid = Raw Sludge, Dewatered Sludge, soil, etc. (reported as mg/l)		G = Glass		<input type="checkbox"/>	PW SID
All containers intact	Y / N	PW = Potable Water (not for SWDA compliance)		O = Other		<input type="checkbox"/>	Fax
Tests within holding times	Y / N	SWDA = Safe Drinking Water Act Potable Sample		<b>Preservative Key</b>		<input type="checkbox"/>	Email
40 ml. VOA vials free of headspace ?	Y / N			H = Sodium			
		<b>Sample Type Key</b>	<b>SWDA Sample Type</b>	Thiosulphate	A = Ascorbic		Other
		G = Grab	D = Distribution	Acid	H = HNO3		
		8 HC = 8 Hour Composite	E = Entry Point	C = HCl	S =		
			R = Raw	H <sub>2</sub> SO <sub>4</sub>	OH = NaOH		
			C = Check	O = Other	NA =		Return a copy of this form with Report
			S = Special	None Required			
			M = Maximum				
			Residence				

11/20/24 Per Chris  
Sampled on  
11/16/24



4K04433  
Lauren Uille

COC Pg 6



### Chain of Custody Record

TAT (Check One)    Standard    24hr    48hr    72hr    Other

1037F MacArthur Road, Reading, PA 19605  
610-375-TEST -- Fax: 610-375-4090 -- suburbantestinglabs.com

Client Name:	Westchester Environmental LLC.			Project Name:	Butler SD
Address:	1248 Wrights Lane	Phone:	610-431-7545	Address:	High School, Decker, & Butler
	West Chester, PA 19380	Email:	cpiccininni@westchesterenviromental.com		38 Bartholdi Ave, Butler, NJ 07405
Contact Name:	Chris Piccininni			Payment / P.O. Info:	

Comments:

Flush / First Draw	Location Code	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type	Preservative	Sample Description / Site ID
First	BAD--FS-Faculty Rm 36	11/20/24	08:54 AM	CMP	051	Pb EPA 200.8	1	PW	G	P	H	Faculty Rm 36
First	BAD-2FL-S-Rm 35	11/20/24	08:56 AM	CMP	052	Pb EPA 200.8	1	PW	G	P	H	Rm 35
First	BAD-2FL-S-Rm 36	11/20/24	08:58 AM	CMP	053	Pb EPA 200.8	1	PW	G	P	H	Rm 36
Flush	BRB-1FL-POE-Boiler Room	11/20/24	09:10 AM	CMP	054	Pb EPA 200.8	1	PW	G	P	H	Boiler Room
First	BRB-1FL-FP-Special Serviss	11/20/24	09:14 AM	CMP	055	Pb EPA 200.8	1	PW	G	P	H	Special Serviss
First	BRB-1FL-FP-Kitchen	11/20/24	09:16 AM	CMP	056	Pb EPA 200.8	1	PW	G	P	H	Kitchen
First	BRB-1FL-FS-Faculty 156	11/20/24	09:18 AM	CMP	057	Pb EPA 200.8	1	PW	G	P	H	Faculty 156
First	BRB-1FL-DW-o/s Rm 153	11/20/24	09:20 AM	CMP	058	Pb EPA 200.8	1	PW	G	P	H	o/s Rm 153
First	BRB-1FL-WC-Hall o/s Special Services-L	11/20/24	09:22 AM	CMP	059	Pb EPA 200.8	1	PW	G	P	H	Hall o/s Special Services-L
First	BRB-1FL-BF-Hall o/s Special Services-R	11/20/24	09:24 AM	CMP	060	Pb EPA 200.8	1	PW	G	P	H	Hall o/s Special Services-R

Relinquished by:	Date:	Time:	Temp °C:
Received By:	Date:	Time:	Acceptable Y / N
Relinquished by:	Date:	Time:	Acceptable Y / N
Received in Lab By:	Date:	Time:	Acceptable Y / N

Sample Conditions	Matrix Key	Bottle Type Key
Submitted w/ COC    Y / N	NPW = Non-Potable Water Solid = Raw Sludge, Dewatered Sludge, soil, etc. (reported as mg/l)	P = Plastic G = Glass O = Other
Number of containers match number on    Y / N	PW = Potable Water (not for SWDA compliance) SWDA = Safe Drinking Water Act Potable Sample	Preservative Key H = Sodium Thiosulphate A = Ascorbic Acid H = HNO3 C = HCl S = H2SO4 OH = NaOH O = Other NA = None Required
All containers intact    Y / N	Sample Type Key G = Grab 8 HC = 8 Hour Composite 24 HC = 24 Hour Composite	SWDA Sample Type D = Distribution E = Entry Point R = Raw C = Check S = Special M = Maximum Residence
Tests within holding times    Y / N		
40 ml. VOA vials free of headspace ?    Y / N		

11/20/24 Per Chris  
Sampled on  
11/16  
LAA



4K04433  
Lauren Ulle



TESTING LABS

Chain of Custody Record

1037F MacArthur Road, Reading, PA 19605  
610-375-TEST - Fax: 610-375-4090 - suburban testinglabs.com

TAT (Check One) Standard 24hr 48hr 72hr Other

Client Name:	Westchester Environmental LLC.			Project Name:	Butler SD
Address:	1248 Wrights Lane	Phone:	610-431-7545	Address:	High School, Decker, & Butler
	West Chester, PA 19380				38 Bartholdi Ave, Butler, NJ 07405
Contact Name:	Chris Piccininni	Email:	cpiccininni@westchesterenvironmental.com	Payment / P.O. Info:	

Comments:

Flush / First Draw	Location Code	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type	Preservative	Sample Description / Site ID
First	BRB-1FL-WC-Hall o/s 119 Left	11/20/24	09:26 AM	CMP	61	Pb EPA 200.8	1	PW	G	P	H	Hall o/s 119 Left
First	BRB-1FL-DW-Hall o/s Nurse-L	11/20/24	09:28 AM	CMP	62	Pb EPA 200.8	1	PW	G	P	H	Hall o/s Nurse-L
First	BRB-1FL-BF-Hall o/s Nurse-R	11/20/24	09:30 AM	CMP	63	Pb EPA 200.8	1	PW	G	P	H	Hall o/s Nurse-R
First	BRB-1FL-WC-Hall o/s Nurse-R	11/20/24	09:32 AM	CMP	64	Pb EPA 200.8	1	PW	G	P	H	Hall o/s Nurse-R
First	BRB-1FL-NS-Nurse	11/20/24	09:34 AM	CMP	65	Pb EPA 200.8	1	PW	G	P	H	Nurse
First	BRB-1FL-WC-Hall o/s Gym-L	11/20/24	09:36 AM	CMP	66	Pb EPA 200.8	1	PW	G	P	H	Hall o/s Gym-L
First	BRB-1FL-BF-Hall o/s Gym-L	11/20/24	09:38 AM	CMP	67	Pb EPA 200.8	1	PW	G	P	H	Hall o/s Gym-L
First	Field Blank	11/20/24	09:40 AM	CMP	68	Pb EPA 200.8	1	PW	G	P	H	Field Blank

Relinquished by:

Date:

Time:

Received By:

Date:

Temp °C:

Time:

Acceptable Y / N

Relinquished by:

Date:

Temp °C:

Time:

Acceptable Y / N

Received in Lab By:

Date:

Temp °C:

Time:

Acceptable Y / N

Sample Conditions	Matrix Key	Bottle Type Key
Submitted w/ COC Y / N	NPW = Non-Potable Water	P = Plastic
Number of containers match number on COC? Y / N	Solid = Raw Sludge, Dewatered Sludge, soil, etc. (reported as mg/l)	G = Glass
All containers intact Y / N	PW = Potable Water (not for SWDA compliance)	O = Other
Tests within holding times Y / N	SWDA = Safe Drinking Water Act Potable Sample	<b>Preservative Key</b>
40 ml. VOA vials free of headspace? Y / N	<b>Sample Type Key</b>	H = Sodium
	<b>SWDA Sample Type</b>	Thiosulphate Acid A = Ascorbic
	G = Grab	H = HNO3
	8 HC = 8 Hour	C = HCl S =
	Composite	H2SO4 OH = NaOH
	C = Check	O = Other
	S = Special	None
	M = Maximum	Required
	Residence	

11/20/24 - per Chris  
Sampled on  
11/16  
UL